



# Indy Safety, Inc.

Offices in Portland & Wilsonville

## Elessar Connolly-Fairchild

### Project Manager

Certified Mold Inspector

EPA, DEQ Asbestos Inspector, Management Planner

EPA/Oregon DPSST Certified HazMat Instructor

OSHA Outreach Trainer

[elessar@indy-safety.com](mailto:elessar@indy-safety.com)

503-481-2193

---

**To:** Mark Dodge, Pam Bonner  
Clackamas Education Service District

**From:** Elessar Connolly-Fairchild, Project Manager, Indy Safety

**Project:** Lead in Drinking Water and Radon Testing Report  
CESD/Main Building, Data Center, Marian Hall  
13455 SE 97th Ave  
Clackamas, OR 97015

**Testing Dates:** May 9, 2023, June 1, 2023, June 23, 2023

**Report Date:** June 30, 2023

---

### Main Building/Data Center

- A total of 35 drinking water samples and 5 retests were collected from the Main Building and the Data Center of the Clackamas Education Service District. Columbia Laboratories completed lead analysis and all main building samples tested below the action limits of 15 ppb for lead. See spreadsheet attached in publishable format for ODE reporting.
  - Two fixtures in the Date Center were above the action limit, retested (five retests) and subsequently decommissioned, pending replacement.
- A total of 33 radon in air samples (including three duplicates and two blanks for quality control) were taken on the First floor of the Main Building. All samples were analyzed by EMSL and all tested below the action limit of 4 pCi/L. See spreadsheet attached in publishable format for ODE reporting.

### Marian Hall

- A total of 15 drinking water samples were collected. Columbia Laboratories completed lead analysis and all samples tested below the action limits of 15 ppb for lead.
- A total of 16 radon in air samples (including one duplicate and one blank for quality control) were taken on the First floor of Marian Hall. All samples were analyzed by EMSL and all tested below the action limit of 4 pCi/L. See spreadsheet attached in publishable format for ODE reporting.

### Reimbursement Docs

- All docs for ODE water testing reimbursement will be attached.

---

**Environmental Testing, Safety Training and Consultation**



12423 NE Whitaker Way  
Portland, OR 97230  
503-254-1794



**Report Number:** 23-005675/D002.R00  
**Report Date:** 05/18/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD  
**Project No:**

### Cover Letter

Indy Safety  
5010 NE Roselawn ST  
Portland Oregon 97218  
United States of America (USA)

Dear Elessar Connolly-Fairchild,

Enclosed please find Columbia Laboratories analytical report for samples received as order number 23-005675 on 05/11/2023 at 12:06. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Thank you for allowing Columbia Laboratories to be of service to you, we appreciate your business.

Sincerely,

Derrick Tanner  
General Manager



12423 NE Whitaker Way  
 Portland, OR 97230  
 503-254-1794



**Report Number:** 23-005675/D002.R00  
**Report Date:** 05/18/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD  
**Project No:**

**Sample Results**

**Sample:** 190200000-01 1KF 23A      Collected: 5/9/23 05:17      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0001      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	1.34	15.000	µg/l	0.2	1.00	2307289		05/12/23 14:35	

**Sample Results**

**Sample:** 190200000-002 1M 23A      Collected: 5/9/23 05:20      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0002      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	< LOQ	15.000	µg/l	0.2	1.00	2307289		05/12/23 14:36	

**Sample Results**

**Sample:** 190200000-003 BF 23A      Collected: 5/9/23 05:23      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0003      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.531	15.000	µg/l	0.2	1.00	2307289		05/12/23 14:38	

**Sample Results**

**Sample:** 190200000-004 BF 23A      Collected: 5/9/23 05:22      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0004      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.976	15.000	µg/l	0.2	1.00	2307289		05/12/23 14:49	

**Sample Results**

**Sample:** 190200000-005 BF 23A      Collected: 5/9/23 05:25      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0005      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.781	15.000	µg/l	0.2	1.00	2307289		05/12/23 14:51	

*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*



12423 NE Whitaker Way  
 Portland, OR 97230  
 503-254-1794



**Report Number:** 23-005675/D002.R00  
**Report Date:** 05/18/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD  
**Project No:**

**Sample Results**

**Sample:** 19020000-006 BF 23A      Collected: 5/9/23 05:24      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0006      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.696	15.000	µg/l	0.2	1.00	2307289		05/12/23 14:53	

**Sample Results**

**Sample:** 19020000-007 DW 23A      Collected: 5/9/23 05:26      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0007      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	< LOQ	15.000	µg/l	0.2	1.00	2307289		05/12/23 14:54	

**Sample Results**

**Sample:** 19020000-008 SF 23A      Collected: 5/9/23 05:30      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0008      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	6.60	15.000	µg/l	0.2	1.00	2307289		05/12/23 14:56	

**Sample Results**

**Sample:** 19020000-009 SF 23A      Collected: 5/9/23 05:32      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0009      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	6.93	15.000	µg/l	0.2	1.00	2307289		05/12/23 14:57	

**Sample Results**

**Sample:** 19020000-010 DW 23A      Collected: 5/9/23 05:35      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0010      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	5.17	15.000	µg/l	0.2	1.00	2307289		05/12/23 14:59	

*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*



12423 NE Whitaker Way  
 Portland, OR 97230  
 503-254-1794



**Report Number:** 23-005675/D002.R00  
**Report Date:** 05/18/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD  
**Project No:**

**Sample Results**

**Sample:** 19020000-011 DW 23A      Collected: 5/9/23 05:37      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0011      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	< LOQ	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:01	

**Sample Results**

**Sample:** 19020000-012 BF 23A      Collected: 5/9/23 05:40      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0012      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.797	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:02	

**Sample Results**

**Sample:** 19020000-013 BF 23A      Collected: 5/9/23 05:41      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0013      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.593	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:04	

**Sample Results**

**Sample:** 19020000-014 BF 23A      Collected: 5/9/23 05:42      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0014      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	1.45	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:15	

**Sample Results**

**Sample:** 19020000-015 BF 23A      Collected: 5/9/23 05:43      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0015      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	3.00	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:17	

*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*



12423 NE Whitaker Way  
 Portland, OR 97230  
 503-254-1794



**Report Number:** 23-005675/D002.R00  
**Report Date:** 05/18/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD  
**Project No:**

**Sample Results**

**Sample:** 09020000-016 BF 23A      Collected: 5/9/23 05:44      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0016      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	10.2	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:18	

**Sample Results**

**Sample:** 19020000-017 BF 23A      Collected: 5/9/23 05:46      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0017      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	5.43	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:20	

**Sample Results**

**Sample:** 19020000-018 BF 23A      Collected: 5/9/23 05:47      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0018      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.809	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:22	

**Sample Results**

**Sample:** 19020000-019 BF 23A      Collected: 5/9/23 05:48      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0019      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.728	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:23	

**Sample Results**

**Sample:** 19020000-020 BF 23A      Collected: 5/9/23 05:49      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0020      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.704	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:25	

*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*



12423 NE Whitaker Way  
 Portland, OR 97230  
 503-254-1794



**Report Number:** 23-005675/D002.R00  
**Report Date:** 05/18/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD  
**Project No:**

**Sample Results**

**Sample:** 19020000-021 BF 23A      Collected: 5/9/23 05:52      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0021      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.719	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:27	

**Sample Results**

**Sample:** 19020000-022 SF 23A      Collected: 5/9/23 05:54      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0022      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	1.52	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:28	

**Sample Results**

**Sample:** 19020000-023 BF 23A      Collected: 5/9/23 05:57      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0023      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	2.91	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:30	

**Sample Results**

**Sample:** 19020000-024 BF 23A      Collected: 5/9/23 05:58      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0024      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	2.07	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:41	

**Sample Results**

**Sample:** 19020000-025 BF 23A      Collected: 5/9/23 05:59      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0025      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.829	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:43	

*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*



12423 NE Whitaker Way  
 Portland, OR 97230  
 503-254-1794



**Report Number:** 23-005675/D002.R00  
**Report Date:** 05/18/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD  
**Project No:**

**Sample Results**

**Sample:** 19020000-026 BF 23A Collected: 5/9/23 06:00 Temp: 20 °C Matrix:  
 Lab ID: 23-005675-0026 Received: 5/11/23 12:06 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	1.86	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:44	

**Sample Results**

**Sample:** 19020000-027 DW 23A Collected: 5/9/23 06:01 Temp: 20 °C Matrix:  
 Lab ID: 23-005675-0027 Received: 5/11/23 12:06 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	4.28	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:46	

**Sample Results**

**Sample:** 19020000-028 SF 23A Collected: 5/9/23 06:02 Temp: 20 °C Matrix:  
 Lab ID: 23-005675-0028 Received: 5/11/23 12:06 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.592	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:48	

**Sample Results**

**Sample:** 19020000-029 DW 23A Collected: 5/9/23 06:04 Temp: 20 °C Matrix:  
 Lab ID: 23-005675-0029 Received: 5/11/23 12:06 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	< LOQ	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:49	

**Sample Results**

**Sample:** 19020000-030 BF 23A Collected: 5/9/23 06:26 Temp: 20 °C Matrix:  
 Lab ID: 23-005675-0030 Received: 5/11/23 12:06 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	59.4	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:51	

*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*



12423 NE Whitaker Way  
 Portland, OR 97230  
 503-254-1794



**Report Number:** 23-005675/D002.R00  
**Report Date:** 05/18/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD  
**Project No:**

**Sample Results**

**Sample:** 19020001-031 BF 23A      Collected: 5/9/23 06:29      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0031      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	11.1	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:52	

**Sample Results**

**Sample:** 19020001-032 KF 23A      Collected: 5/9/23 06:31      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0032      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	502	15.000	µg/l	2.0	10.00	2307349		05/16/23 13:26	

**Sample Results**

**Sample:** 19020001-033 BF 23A      Collected: 5/9/23 06:33      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0033      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.608	15.000	µg/l	0.2	1.00	2307289		05/12/23 15:56	

**Sample Results**

**Sample:** 19020000-034 SF 23A      Collected: 5/9/23 06:35      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0034      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	< LOQ	15.000	µg/l	0.2	1.00	2307289		05/12/23 16:07	

**Sample Results**

**Sample:** 19020000-035 SF 23A      Collected: 5/9/23 06:37      Temp: 20 °C      Matrix:  
 Lab ID: 23-005675-0035      Received: 5/11/23 12:06      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	0.686	15.000	µg/l	0.2	1.00	2307289		05/12/23 16:09	

**Units of Measure**

µg/l = micrograms per liter

*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*



12423 NE Whitaker Way  
Portland, OR 97230  
503-254-1794



**Report Number:** 23-005675/D002.R00  
**Report Date:** 05/18/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD  
**Project No:**

**Abbreviations**

LOQ Limit of quantification

¥ = TNI accredited analyte.

---









12423 NE Whitaker Way  
Portland, OR 97230  
503-254-1794



**Report Number:** 23-005675/D002.R00  
**Report Date:** 05/18/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD  
**Project No:**



**Environmental Chain of Custody Record**

Revision: 4.00 Document Control: CF001  
Revised: 01/18/2021 Effective: 03/16/2021

Please inform us if you know or suspect that any part of your sample may contain hazardous materials or chemicals.

Company: <u>INDY SAFETY</u> Contact: <u>ELESSAR CONNOLLY FARREHAN</u> Address: <u>5010 NE BUSELAW</u> <u>PORTLAND, OR 97218</u> Email: <u>ELESSAR@INDYSAFETY.COM</u> Phone: <u>(503) 281-2193</u> Fax: ( )		Analysis Requested (Vertical text: <u>CESD</u> )		PO Number: _____ Project Number: _____ Project Name: <u>CESD</u> Custom Reporting: _____ <input type="checkbox"/> Report to State: _____ Turn-around time: <input checked="" type="checkbox"/> Standard <input type="checkbox"/> Other, Due: _____ Rush: <input type="checkbox"/> 4 day <input type="checkbox"/> 3 day <input type="checkbox"/> 2 day <input type="checkbox"/> Next day *Ask for availability. Samples received after 3pm are considered as received the following business day.	
Billing (if different): _____		Preservative codes: Verification of type used: _____		Sampled by: <u>ELESSAR CONNOLLY-FARREHAN</u>	
Lab #	Field / Sample ID	Date/Time	Matrix #	Comments	
	<u>19020000-031 BF 23A</u>	<u>5-23-23 629</u>		<u>#8417 x 35</u> <u>#8417 x 34</u> <u>#8414 x 1</u>	
	<u>19020000-032 KF 23A</u>	<u>631</u>			
	<u>19020000-033 BF 23A</u>	<u>633</u>			
	<u>19020000-034 GF 23A</u>	<u>635</u>			
	<u>19020000-035 GF 23A</u>	<u>637</u>			
	<del>19020000-23A</del>				
Relinquished By:	Date	Time	Received By:	Date	Time
<u>ELESSAR CONNOLLY-FARREHAN</u>	<u>5/18/23</u>	<u>12:06</u>	<u>[Signature]</u>	<u>5/11/23</u>	<u>12:06</u>
<input type="checkbox"/> Shipped Via: _____ or <input checked="" type="checkbox"/> Client drop off Evidence of cooling: <input type="checkbox"/> yes   <input checked="" type="checkbox"/> No - Temp (°C): <u>20.0</u> If temp out, proceed?: <input type="checkbox"/> yes   <input checked="" type="checkbox"/> No <input type="checkbox"/> Cash   <input type="checkbox"/> Check   <input type="checkbox"/> CC   <input type="checkbox"/> Net: _____					

Samples submitted to CL with testing requirements constitute an agreement for services in accordance with the current terms of service associated with this COC. By signing "Relinquished by" you are agreeing to these terms.

12423 NE Whitaker Way  
Portland, OR 97230

P: (503) 254-1794 | Fax: (503) 254-1452  
Info@columbiainlaboratories.com

Page 4 of 4  
www.columbiainlaboratories.com



12423 NE Whitaker Way  
Portland, OR 97230  
503-254-1794



**Report Number:** 23-005675/D002.R00  
**Report Date:** 05/18/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD  
**Project No:**

### Case Narrative

No Case Narrative notes to report.



12423 NE Whitaker Way  
Portland, OR 97230  
503-254-1794



**Report Number:** 23-006483/D002.R00  
**Report Date:** 06/05/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD Retests  
**Project No:**

### Cover Letter

Indy Safety  
5010 NE Roselawn ST  
Portland Oregon 97218  
United States of America (USA)

Dear Elessar Connolly-Fairchild,

Enclosed please find Columbia Laboratories analytical report for samples received as order number 23-006483 on 06/01/2023 at 09:31. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Thank you for allowing Columbia Laboratories to be of service to you, we appreciate your business.

Sincerely,

Derrick Tanner  
General Manager



12423 NE Whitaker Way  
 Portland, OR 97230  
 503-254-1794



**Report Number:** 23-006483/D002.R00  
**Report Date:** 06/05/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD Retests  
**Project No:**

**Sample Results**

<b>Sample:</b> 19020001-30 BF 23A	Collected: 6/1/23 07:00	Temp: 19.1 °C	Matrix:
Lab ID: 23-006483-0001	Received: 6/1/23 09:31	Evidence of Cooling: N	Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	43.5	15.000	µg/l	0.2	1.00	2307870		06/02/23 13:55	

**Sample Results**

<b>Sample:</b> 19020001-32 KF 23A	Collected: 6/1/23 07:05	Temp: 19.1 °C	Matrix:
Lab ID: 23-006483-0002	Received: 6/1/23 09:31	Evidence of Cooling: N	Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	77.5	15.000	µg/l	0.2	1.00	2307870		06/02/23 13:56	

**Units of Measure**

µg/l = micrograms per liter

**Abbreviations**

LOQ Limit of quantification

\* = TNI accredited analyte.



12423 NE Whitaker Way  
 Portland, OR 97230  
 503-254-1794



Report Number: 23-006483/D002.R00  
 Report Date: 06/05/2023  
 ORELAP#: OR100028  
 Purchase Order:  
 Project Name: CESD Retests  
 Project No:



Environmental Chain of Custody Record

Revision: 4.00 Document Control: CF001  
 Revised: 01/18/2021 Effective: 03/16/2021

INDYSAFE 23-006483



Indy Safety

Please Inform us if you know or suspect that any part of your sample may contain hazardous materials or chemicals

Company: <u>INDY SAFETY</u> Contact: <u>ELESSAR CONNOR FAIRCHILD</u> Address: <u>5010 NE BUSELANA</u> <u>PORTLAND, OR 97218</u> Email: <u>ELESSAR@INDYSAFETY.COM</u> Phone: <u>(503) 481-2193</u> Fax: ( )			Analysis Requested (Grid with handwritten 'LEAD' in the first column)			PO Number: _____ Project Number: _____ Project Name: <u>CESD RETESTS</u> Custom Reporting: _____ <input type="checkbox"/> Report to State: _____ Turn-around time: <input checked="" type="checkbox"/> Standard <input type="checkbox"/> Other, Due: _____ Rush: <input type="checkbox"/> 4 day <input checked="" type="checkbox"/> 3 day <input type="checkbox"/> 2 day <input type="checkbox"/> Next day *Ask for availability. Samples received after 3pm are considered as received the following business day.		
Billing (if different): _____			Preservative code: Verification of type listed †			Sampled by: <u>ELESSAR CONNOR FAIRCHILD</u>		
Lab #	Field / Sample ID	Date/Time	Matrix #	Comments				
	<u>19020001-30 BF 23A</u>	<u>6-1-23 7:00</u>		PLEASE ONLY ANALYZE "B" SAMPLE IF "A" SAMPLE IS OVER LIMIT.				
	<u>19020001-30 BF 23B</u>	<u>6-1-23 7:00</u>						
	<u>19020001-32 KF 23A</u>	<u>6-1-23 7:05</u>						
	<u>19020001-32 KF 23B</u>	<u>6-1-23 7:05</u>						
Relinquished By:	Date	Time	Received By:	Date	Time	Lab Use Only		
<u>E. Connor Fairchild</u>	<u>6/1/23</u>	<u>8:00 AM</u>	<u>WFTW</u>	<u>6/1/23</u>	<u>9:31</u>	<input type="checkbox"/> Shipped Via: _____ or <input checked="" type="checkbox"/> Client drop off Evidence of cooling: <input type="checkbox"/> yes   <input checked="" type="checkbox"/> No - Temp (°C): <u>PL1</u> If temp out, proceed?: <input type="checkbox"/> yes   <input type="checkbox"/> No _____ <input type="checkbox"/> Cash   <input type="checkbox"/> Check   <input type="checkbox"/> CC   <input type="checkbox"/> Net: _____		

Samples submitted to CL with testing requirements constitute an agreement for services in accordance with the current terms of service associated with this COC. By signing "Relinquished by" you are agreeing to these terms.

12423 NE Whitaker Way  
 Portland, OR 97230

P: (503) 254-1794 | Fax: (503) 254-1452  
 info@columbiaboratories.com

Page 1 of 1  
 www.columbiaboratories.com



12423 NE Whitaker Way  
Portland, OR 97230  
503-254-1794



**Report Number:** 23-006483/D002.R00  
**Report Date:** 06/05/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD Retests  
**Project No:**

### Case Narrative

No Case Narrative notes to report.



12423 NE Whitaker Way  
Portland, OR 97230  
503-254-1794



**Report Number:** 23-006592/D002.R00  
**Report Date:** 06/07/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD Retests  
**Project No:**

### Cover Letter

Indy Safety  
5010 NE Roselawn ST  
Portland Oregon 97218  
United States of America (USA)

Dear Elessar Connolly-Fairchild,

Enclosed please find Columbia Laboratories analytical report for samples received as order number 23-006592 on 06/01/2023 at 09:31. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Thank you for allowing Columbia Laboratories to be of service to you, we appreciate your business.

Sincerely,

Derrick Tanner  
General Manager



12423 NE Whitaker Way  
 Portland, OR 97230  
 503-254-1794



**Report Number:** 23-006592/D002.R00  
**Report Date:** 06/07/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD Retests  
**Project No:**

**Sample Results**

**Sample:** 19020001-30 BF 23B      Collected: 6/1/23 07:00      Temp: 19.1 °C      Matrix:  
 Lab ID: 23-006592-0001      Received: 6/1/23 09:31      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	2.32	15.000	µg/l	0.2	1.00	2307927		06/05/23 14:47	

**Sample Results**

**Sample:** 19020001-32 KF 23B      Collected: 6/1/23 07:05      Temp: 19.1 °C      Matrix:  
 Lab ID: 23-006592-0002      Received: 6/1/23 09:31      Evidence of Cooling: N      Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	25.0	15.000	µg/l	0.2	1.00	2307927		06/05/23 14:48	

**Units of Measure**

µg/l = micrograms per liter

**Abbreviations**

LOQ Limit of quantification

\* = TNI accredited analyte.



12423 NE Whitaker Way  
 Portland, OR 97230  
 503-254-1794



23020013

Report Number: 23-006592/D002.R00  
 Report Date: 06/07/2023  
 ORELAP#: OR100028  
 Purchase Order:  
 Project Name: CESD Retests  
 Project No:



Environmental Chain of Custody Record

Revision: 4.00 Document Control: CF001  
 Revised: 01/18/2021 Effective: 03/16/2021



23-006592

Please inform us if you know or suspect that any part of your sample may contain hazardous materials.

Company: <u>INDY SAFETY</u>			Analysis Requested:			Indy Safety																										
Contact: <u>ELESSAR CONNOLLY FARREHAN</u>			<table border="1"> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>																											RU number: _____		
Address: <u>5010 NE BURLAND</u>			Project Number: _____			Project Name: <u>CESD RETESTS</u>																										
<u>PORTLAND, OR 97218</u>			Custom Reporting: _____			Report to State: <input type="checkbox"/>																										
Email: <u>ELESSAR@INDYSAFETY.COM</u>			Turn-around time: <input checked="" type="checkbox"/> Standard <input type="checkbox"/> Other, Due: _____			Rush: <input type="checkbox"/> 4 day <input checked="" type="checkbox"/> 3 day <input type="checkbox"/> 2 day <input type="checkbox"/> Next day																										
Phone: <u>(503) 481-2193</u> Fax: _____			*Ask for availability. Samples received after 3pm are considered as received the following business day.			Sampled by: <u>ELESSAR CONNOLLY-FARREHAN</u>																										
Billing (if different): _____			Preservative code: Verification of type used:			Matrix #:																										
Lab #	Field / Sample ID	Date / Time	Matrix #	Comments																												
	<u>19020001-30 BF 23A</u>	<u>6-1-23 7:00</u>		PLEASE ONLY ANALYZE "B" SAMPLE IF "A" SAMPLE IS OVER LIMIT.																												
	<u>19020001-30 BF 23B</u>	<u>6-1-23 7:00</u>																														
	<u>19020001-32 KF 23A</u>	<u>6-1-23 7:05</u>																														
	<u>19020001-32 KF 23B</u>	<u>6-1-23 7:05</u>																														
Relinquished By	Date	Time	Received By	Date	Time	Lab Use Only																										
<u>E. Connolly Farrehan</u>	<u>6-1-23</u>	<u>8:00p</u>	<u>WFA</u>	<u>10/1/23</u>	<u>9:31</u>	<input type="checkbox"/> Shipped Via: _____ or <input checked="" type="checkbox"/> Client drop off Evidence of cooling: <input type="checkbox"/> yes   <input checked="" type="checkbox"/> No - Temp (°C): <u>PL</u> If temp out, proceed?: <input type="checkbox"/> yes   <input type="checkbox"/> No <input type="checkbox"/> Cash   <input type="checkbox"/> Check   <input type="checkbox"/> CC   <input type="checkbox"/> Net: _____																										

Samples submitted to CL with testing requirements constitute an agreement for services in accordance with the current terms of service associated with this COC. By signing "Relinquished by" you are agreeing to these terms.

12423 NE Whitaker Way  
 Portland, OR 97230

P: (503) 254-1794 | Fax: (503) 254-1452  
 info@columbiaboratories.com

Page 1 of 1  
 www.columbiaboratories.com



12423 NE Whitaker Way  
Portland, OR 97230  
503-254-1794



**Report Number:** 23-006592/D002.R00  
**Report Date:** 06/07/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD Retests  
**Project No:**

### Case Narrative

No Case Narrative notes to report.



12423 NE Whitaker Way  
Portland, OR 97230  
503-254-1794



**Report Number:** 23-007486/D001.R00  
**Report Date:** 06/26/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD-Main Bldg  
**Project No:** Data Ctr

### Cover Letter

Sirius Safety  
Elessar Connolly-Fairchild  
37811 SE Wildcat Mt Dr  
Eagle Creek Oregon 97022  
United States of America (USA)

Dear Elessar Connolly-Fairchild,

Enclosed please find Columbia Laboratories analytical report for samples received as order number 23-007486 on 06/23/2023 at 12:22. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Thank you for allowing Columbia Laboratories to be of service to you, we appreciate your business.

Sincerely,

Derrick Tanner  
General Manager



12423 NE Whitaker Way  
Portland, OR 97230  
503-254-1794



**Report Number:** 23-007486/D001.R00  
**Report Date:** 06/26/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD-Main Bldg  
**Project No:** Data Ctr

### Sample Results

<b>Sample:</b> 19020001-030BF23A	Collected: 6/23/23 09:45	Temp: 23 °C	Matrix:
Lab ID: 23-007486-0001	Received: 6/23/23 12:22	Evidence of Cooling: N	Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead <sup>‡</sup>	57.9	15.000	µg/l	0.2	1.00	2308553		06/26/23 14:19	

#### Units of Measure

µg/l = micrograms per liter

#### Abbreviations

LOQ Limit of quantification

<sup>‡</sup> = TNI accredited analyte.





12423 NE Whitaker Way  
Portland, OR 97230  
503-254-1794



**Report Number:** 23-007486/D001.R00  
**Report Date:** 06/26/2023  
**ORELAP#:** OR100028  
**Purchase Order:**  
**Project Name:** CESD-Main Bldg  
**Project No:** Data Ctr

### Case Narrative

No Case Narrative notes to report.