

CESD Admin

Radon Tests

Collected 7/30 - 8/6 2016

| Sample Number | Location | EPA/OHA Action | | Retest 8/6/16 | Retest average |
|---------------|-------------------|-------------------------|-------------------|---------------|----------------|
| | | 7/30 Result in pCi/L | Limit in pCi/L | | |
| CESD-01 | Room 134 | 0.7 | 4 | | |
| CESD-02 | Conference rm | 1.2 | 4 | | |
| CESD-03 | Room 153 | 1.5 | 4 | | |
| CESD-04 | Room 154 | 3.4 | 4 | | |
| CESD-05 | Room 156 | 2.7 | 4 | | |
| CESD-06 | Room 157 | 2.2 | 4 | | |
| CESD-07 | Room 161 | 1.9 | 4 | No RT unocc | |
| CESD-08 | Room 162 | 2.5 | 4 | | |
| CESD-09 | Room 160 | 4.8 | 4 | No RT unocc | |
| CESD-10 | Room 159 | 2.6 | 4 | | |
| CESD-10A | Room 159 | 2.5 | 4 | | |
| CESD-11 | Room 158 | 3.2 | 4 | | |
| CESD-12 | Brightwood | 0.9 | 4 | | |
| CESD-13 | Springwater | 2.3 | 4 | | |
| CESD-14 | Room 142 | Missing | 4 | 1.8 | |
| CESD-15 | New Era | 3.6 | 4 | | |
| CESD-16 | Room 120 | 3.5 | 4 | | |
| CESD-17 | Room 119 | 2.1 | 4 | | |
| CESD-18 | Room 118 | 4.2 | 4 | 2.8 | |
| CESD-19 | Room 117 | 3.1 | 4 | | 3.5 |
| CESD-20 | Room 116 | 5 | 4 | 3.1 | 4.05 |
| CESD-20A | Room 116 | 5 | 4 | duplicate | |
| CESD-21 | Room 115 | 1.9 | 4 | | |
| CESD-22 | Room 114 | 2.6 | 4 | | |
| CESD-23 | Room 104 | Missing | 4 | 1.2 | |
| CESD-24 | Room 105 | 1 | 4 | | |
| CESD-25 | Room 102 Printing | 0.9 | 4 | | |
| CESD-26 | Room 102 Printing | 0.9 | 4 | | |
| CESD-27 | Room 109 | Missing | 4 | 1.7 | |
| CESD-28 | Room 111 Vault | 5.2 | 4 | No RT unocc | |
| CESD-29 | Room 112 | 3.2 | 4 | | |
| CESD-30 | Hallway | 1.5 | 4 | | |
| CESD-30A | Hallway | 1.4 | 4 | | |
| CESD-31 | Room 123 | Missing | 4 | 2.4 | |
| CESD-32 | Room 124 | Missing | 4 | 2.7 | |
| CESD-33 | Room 125 | Missing | 4 | 2.8 | |
| CESD-34 | Room 127 | Missing | 4 | 2.9 | |
| CESD-35 | Hallway | 2 | 4 | | |
| CESD-36 | Hallway | Missing | 4 | 2.2 | |
| CESD-37 | Blank | 0 | | | |
| CESD-38 | Blank | 0 | | | |

| | | | | | |
|----------|-----------------|--|--|---------------|--|
| CESD 10A | Dup 8/6 testing | | | Add'l dup 2.2 | |
| | | | | | |
| | | | | | |