

Sample name	Location		Test Date	Lead Result ppb	Lead Limit ppb	Copper Result	Copper Limit	Current Recommended Action
CESD-DW-01	Staff Room Third Floor	Food prep	7/30/2016	0.8	15	0.203	1.3	Ok - no action
CESD-DW-02	Staff Room Third Floor	Food prep	7/30/2016	5.1	15	0.222	1.3	Ok - no action
CESD-DS-03	Brightwood Conf Room	Other Human Consumption	7/30/2016	1.9	15	0.2	1.3	Ok - no action
CESD-DF-04	New Etra Conf Room	Other Human Consumption	7/30/2016	4.1	15	0.0863	1.3	Ok - no action
CESD-DWS-05	Springwater Conf Room	Other Human Consumption	7/30/2016	0.8	15	0.192	1.3	Ok - no action
CESD-KSC-06	Kitchen First Floor Cold	Food prep	7/30/2016	0.7	15	0.14	1.3	Ok - no action
CESD-KSH-07	Kitchen First Floor Hot	Food prep	7/30/2016	0.5	15	0.122	1.3	Ok - no action
CESD-DF-08	Drinking fountain Second Floor	Drinking	7/30/2016	1	15	0.0904	1.3	Ok - no action

Sample Name	Location		Test Date	Lead Result ppb	Lead Limit ppb	Copper Result	Copper Limit	Current Recommended Action
CESD-SM-01	Room 137 Womens Bathroom Sink 1	Other Human Consumption	8/6/2016	1.8	15	0.165	1.3	Ok - no action
CESD-SM-02	Room 137 Womens Bathroom Sink 2	Other Human Consumption	8/6/2016	0.9	15	0.131	1.3	Ok - no action
CESD-SM-03	Room 138 Mens Bathroom Sink 1	Other Human Consumption	8/6/2016	1.2	15	0.178	1.3	Ok - no action
CESD-SM-04	Room 138 Mens Bathroom Sink 2	Other Human Consumption	8/6/2016	1.1	15	0.174	1.3	Ok - no action
CESD-KSC-05	Printing Room 102 Cold	Other Human Consumption	8/6/2016	4.2	15	0.503	1.3	Ok - no action
CESD-KSH-06	Printing Room 102 Hot	Other Human Consumption	8/6/2016	1.6	15	0.371	1.3	Ok - no action
CESD-SM-07	Room 259 Bathroom	Other Human Consumption	42588	0.4	15	0.136	1.3	Ok - no action
CESD-SM-08	Room 258 Bathroom	Other Human Consumption	8/6/2016	1.5	15	0.287	1.3	Ok - no action
CESD-SM-09	Room 236 Womens Bathroom	Other Human Consumption	8/6/2016	0.6	15	0.101	1.3	Ok - no action
CESD-SM-10	Room 239 Mens Bathroom	Other Human Consumption	8/6/2016	0.5	15	0.0928	1.3	Ok - no action
CESD-SM-11	Rock Creek Conf Rm Bathroom	Other Human Consumption	8/6/2016	1.7	15	0.138	1.3	Ok - no action
CESD-SM-12	Room 224 Mens Bathroom Sink 1	Other Human Consumption	8/6/2016	2.3	15	0.0971	1.3	Ok - no action
CESD-SM-13	Room 224 Mens Bathroom Sink 2	Other Human Consumption	8/6/2016	1	15	0.105	1.3	Ok - no action
CESD-SM-14	Room 223 Womens Bathroom Sink 1	Other Human Consumption	8/6/2016	0.4	15	0.0949	1.3	Ok - no action
CESD-SM-15	Room 223 Womens Bathroom Sink 2	Other Human Consumption	8/6/2016	0.9	15	0.091	1.3	Ok - no action
CESD-SM-16	Room 221 Bathrom	Other Human Consumption	8/6/2016	0.7	15	0.34	1.3	Ok - no action
CESD-KSC-17	Room 201 Cold	Other Human Consumption	8/6/2016	5.7	15	0.424	1.3	Ok - no action
CESD-KSH-18	Room 201 Hot	Other Human Consumption	8/6/2016	1.3	15	0.223	1.3	Ok - no action
CESD-SM-19	Room 313 Mens Bathroom Sink 1	Other Human Consumption	8/6/2016	1.9	15	0.139	1.3	Ok - no action
CESD-SM-20	Room 313 Mens Bathroom Sink 2	Other Human Consumption	8/6/2016	3.2	15	0.136	1.3	Ok - no action
CESD-SM-21	Room 311 Womens Bathroom Sink 1	Other Human Consumption	8/6/2016	0.7	15	0.134	1.3	Ok - no action
CESD-SM-22	Room 311 Womens Bathroom Sink 2	Other Human Consumption	8/6/2016	0.4	15	0.125	1.3	Ok - no action