



Indy Safety, Inc.

Offices in Portland & Wilsonville

Elessar Connolly-Fairchild

Project Manager

Certified Mold Inspector

EPA, DEQ Asbestos Inspector, Management Planner

EPA/Oregon DPSST Certified HazMat Instructor

OSHA Outreach Trainer

elessar@indy-safety.com

503-481-2193

To: Rod Bashor, Clackamas Education Service District

From: Elessar Connolly-Fairchild, Project Manager, Indy Safety

Project: Lead and Copper in Drinking Water and Radon Testing Report

CESD/North Building
13435 SE 97th Ave
Clackamas, OR 97015

Testing Date: 9/27/22

Report Date: 10/10/22

A total of 16 drinking water samples were collected from the North Building of the Clackamas Education Service District. Columbia Laboratories completed lead and copper analysis and all samples tested below the action limits of 15 ppb for lead and 1.3 ppm for copper. See spreadsheet below.

A total of 13 radon in air samples (including one duplicate and one blank for quality control) were taken in the basement of the North Building. All samples were analyzed by EMSL and all tested below the action limit of 4 pCi/L. See spreadsheet below.

Full lab reports will be submitted with final report when all testing is complete. All excel sheets will be completed with Oregon Department of Education sample numbering system when provided, and will be submitted at the completion of testing.

Clackamas Education Service District--Drinking Water						
Facility	Building	Sample #	Fixture Type	ODE ID #	Lead	Copper
					Action Limit 15 ppb	Action Limit 1.3 ppm
CESD	North	1	BF		2.29	0.019
CESD	North	2	DW		1.13	0.065
CESD	North	3	BF		4.59	0.015
CESD	North	4	BF		2.12	0.02
CESD	North	5	BF		4.21	0.056
CESD	North	6	BF		5.17	0.024
CESD	North	7	BF		3.62	0.022
CESD	North	8	BF		2.35	0.003
CESD	North	9	BF		2.49	0.035
CESD	North	10	BF		0.72	0.011
CESD	North	11	BF		1.71	0.016
CESD	North	12	BF		0.65	0.012
CESD	North	13	BF		0.74	0.013
CESD	North	14	KF		0.88	0.065
CESD	North	15	KF		2.35	0.016
CESD	North	16	KF		5.58	0.021

Clackamas Education Service District -- Radon				
Facility	Building	Sample #	Location	Radon
				Action Limit 4 pCi/L
CESD	North	1	Breakroom	0.8
CESD	North	2	Conf Rm 1	0.4
CESD	North	3	Conf Rm 2	0.4
CESD	North	4	Office off conf rm-R	0.2
CESD	North	5	Office off conf rm-L	0.5
CESD	North	6	Lobby	0.3
CESD	North	7	Workroom	0.2
CESD	North	8	Reception	0.4
CESD	North	9	Office off large rm	0.3
CESD	North	10	Large rm 1	0.4
CESD	North	11	Duplicate (QC)	0.2
CESD	North	12	Large rm 2	0.2
CESD	North	13	Blank	0.1